



TENAGA NASIONAL BERHAD (200866-W)

Nama Pencawang	: PE PASARAYA UPT MACHANG	BCE	:	DATE	
Functional Location	: DMAC/PCE/J00250	RCB	:		Functional Test (Plant - RCB)
Kawasan	: MACHANG	Work	:		Local Test (Plant - RCB - RTU)
Koordinat	:	Comms	:		Integration test (RCB - RTU - Master)
Jenis Pencawang	:				Commissioning Test (Plant - RTU/FTU - Master)
Jenis Comms	: DSR				
CAASDU	:	RTU/FTU Brand	:		: DONG FANG
DTU ID	:	RTU/FTU Serial No.	:		: RMU BJ0115
SIM CARD No	:	RTU/FTU No.	:		: TNB131/2024
IP Address	:	RTU / FTU Protocol	:		: IEC101

SIGNAL	FEEDER												DETAILS RTU				
	DMC 07159	DMC 07160	DMC 07161										RTU/FTU	BCE 1	BCE 2	SAT Form	: Ada
																Master sheet	: Ada
																As Built Drawing	: Ada
INDICATION													DETAILS PIW				
CB OPEN	✓	✓	✓													No. PIW	
CB CLOSE	✓	✓	✓													Wiring List	: ADA
PROT. ALARM																	
SUPER/REMOTE	✓	✓	✓													As Built Drawing	: ADA
OVERCURRENT																RCB Brand	SATRIA
EARTHFAULT																RCB No.	
IRF																No of RCB	1
EARTH SWITCH	✓	✓	✓													RCB 1 Serial No.	
EFI OPERATED	✓	✓														RCB 2 Serial No.	
C.E.S													✓			RCB 3 Serial No.	
CHARGER ALARM														✓		BCE 1 Brand	BERKAT INSAF
AC FAIL														✓		BCE 1 No.	
DC LV																BCE 1 Serial No.	
TCS																	
ANALOG													No. Feeder	Feeder Name			
CT RATIO	300 / 5	300 / 5	300 / 5													DMC 07159	PE UPTOWN MACHANG NO 2
															DMC 07160	SSU UPTOWN MACHANG	
															DMC 07161	TX NO1 1000KVA	
AMP 0%																	
AMP 50%																	
AMP 100%																	
CONTROL																	
CB CTRL OPEN	✓	✓	✓														
CB CTRL CLOSE	✓	✓	✓														
EFI RESET	✓	✓															

PIC Tapak : AZRIN PIC MASTER :